



LAKE • GEORGE
WATERKEEPER®

PO Box 591, Lake George, NY 12845
Tel: (518) 668-5913 Fax: (518)-668-5915
Email: info@lakegeorgewaterkeeper.org
www.lakegeorgewaterkeeper.org

June 8, 2009

Mr. Keith Hanchett, Chairman
Town of Lake George Planning Board
Old Post Road
Lake George, NY 12845

Re: Bazar 2067 State Route 9N (276.00-2-11 & 276.02-1-1)
Site Plan Review #52-2008

Dear Mr. Hanchett:

The Lake George Waterkeeper has reviewed the revised material submitted for the above referenced site plan application. The Waterkeeper supported the applicant's variance requests to prevent the increase of disturbance, especially in close proximity to a tributary to West Brook. The Waterkeeper recognizes the effort of the applicant to incorporate the existing forested soils for stormwater management, which could be a good demonstration project for future development. We would recommend the remainder of the project continue to minimize proposed disturbance limits and design the project within the existing landscape. The Lake George Waterkeeper would like to offer the following comments for consideration:

ACCESS ROAD:

- 1. Additional erosion and sedimentation control details should be added for the access road regrading when located in close proximity to the stream.**

BUILDING SITES:

- 1. Each of the building sites proposes significant amounts of fill and earthwork for the site design.**

The Waterkeeper recommends the proposed development should work with the existing site conditions utilizing the existing soils and site features for stormwater management instead of altering the site to accommodate the proposed buildings.

- 2. Could the existing depression in the northwestern area of the cabin site be used for stormwater management instead of 4 feet of fill being installed creating a depression in the same vicinity?**



THE FUND for LAKE GEORGE

3. **The infiltration of the eave trench will be compromised due to impacts to the soil from construction and tends to be a maintenance problem and therefore is not recommended.**
4. **Basin for the proposed house requires a 3 foot cut which will be below the seasonal high groundwater elevation at 29" indicated in TP-6.**

Thank you for the consideration. I look forward to continuing to work with the Town of Lake George Planning Board in defending the natural resources of Lake George and its watershed.

Sincerely,

A handwritten signature in black ink that reads "Chris Navitsky". The signature is written in a cursive, flowing style.

Christopher Navitsky, PE
Lake George Waterkeeper

cc: Michael White – Lake George Park Commission